

1.	Unique identification code of the product-type	FDMR 60
2.	Products	Dampers – Fire dampers
	Intended use	Fire safety. To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications TPM 142/19
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 mandik@mandik.cz , www.mandik.cz
5.	System of AVCP	System 1
6.	Harmonised standard	EN 15650:2010
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2024/0162 Assessment Report of Performance of Construction Product No. P-1391-CPR-2024/0162

7a.	Declared performances – fire resistance classification Essential characteristics in accordance with EN 15650:2010, art. 4.1.1	
	<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>
		<i>Performance – class of fire resistance ²⁾</i>
Solid wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum ¹⁾	EI 60 (v _e) S [V/H]
	Ablative coated batt ¹⁾	
	2 to 4 dampers in one opening – mortar or gypsum ¹⁾	EI 45 (v _e) S [V/H]
Solid wall construction – damper remote from the wall – 100 mm min. wall thickness	2 to 4 dampers in one opening – ablative coated batt ¹⁾	EI 60 (v _e) S [V/H]
	ISOVER ULTIMATE PROTECT – ablative coated batt ¹⁾	
Gypsum plasterboard wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum ¹⁾	EI 60 (v _e) S [V/H]
	Ablative coated batt ¹⁾	
	2 to 4 dampers in one opening – mortar or gypsum ¹⁾	EI 45 (v _e) S [V/H]
Gypsum plasterboard wall construction – damper remote from the wall – 100 mm min. wall thickness	2 to 4 dampers in one opening – ablative coated batt ¹⁾	EI 60 (v _e) S [V/H]
	ISOVER ULTIMATE PROTECT – ablative coated batt ¹⁾	
Solid ceiling construction – damper in the ceiling – 150 mm min. ceiling thickness	Mortar or gypsum ¹⁾	EI 60 (h _o) S [H]
	Ablative coated batt ¹⁾	

(table continues)

¹⁾ Refer to [Technical documentation](#) for the details of the installation type / installation system.

²⁾ Fire resistance class marking in accordance with Commission regulation (EU) 2024/1681.

(continuation of the table)

<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Performance – class of fire resistance ²⁾</i>
Solid ceiling construction – damper remote from the ceiling – 150 mm min. ceiling thickness	ISOVER ULTIMATE PROTECT – ablative coated batt ¹⁾	EI 60 (h _o) S [H]
Sandwich wall construction – damper in the wall – 100 mm min. wall thickness	Ablative coated batt with cladding board ¹⁾	EI 60 (v _e) S [V/H]
Sandwich wall construction – damper remote from the wall – 100 mm min. wall thickness	ISOVER ULTIMATE PROTECT – ablative coated batt ¹⁾	EI 60 (v _e) S [V/H]
Gypsum plasterboard shaft construction – damper in the wall – 105 mm min. wall thickness	Gypsum plasterboard shaft construction closed from one side – ablative coated batt ¹⁾	EI 60 (v _e) S [V/H]

¹⁾ Refer to [Technical documentation](#) for the details of the installation type / installation system.

²⁾ Fire resistance class marking in accordance with Commission regulation (EU) 2024/1681.

7b. Declared performances – essential characteristics		
<i>Essential characteristics</i>	<i>Requirements (provisions of the harmonised standard EN 15650:2010)</i>	<i>Performance (lever or class) / Compliance with the requirements</i>
Nominal activation conditions/sensitivity:	4.2.1.2	Conforms
– sensing element load bearing capacity	4.2.1.2.2	Conforms
– sensing element response temperature	4.2.1.2.3	Conforms
Response delay (response time): – closure time	4.2.1.3	Conforms
Operational reliability: – cycling	4.3.1, a)	50 cycles – conforms
Durability of response delay: – sensing element response to temperature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	Conforms
Durability of operational reliability: – opening and closing cycle tests	4.3.3.2	Damper with control mechanism - MANDÍK M: NPD - MANDÍK MODULAR: C ₃₀₀ - BELIMO, SCHISCHEK: C _{10.000}

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 2025-01-02



Mgr. Jan Mičan
CEO, Ppa
MANDÍK, a.s.

Declared performances – other characteristics		
<i>Characteristics</i>	<i>Technical standard</i>	<i>Performance (lever or class) / Compliance with the requirements</i>
Resistance against corrosion	EN 15650:2010, art. 4.2.2 EN 15650:2010, Annexe B	Conforms
Damper blade tightness	EN 1751:2024	Class 3
Damper casing tightness	EN 1751:2024	Class ATC 3 (former marking "C")