

1.	Unique identification code of the product-type	<b>SEDM-D</b>
2.	Products	Smoke control dampers
	Intended use	Smoke control dampers that are to be used in multi compartment smoke control systems, either at 600 °C or under fire conditions
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications <a href="#">TPM 155/22</a>
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 <a href="mailto:mandik@mandik.cz">mandik@mandik.cz</a> , <a href="http://www.mandik.com">www.mandik.com</a>
5.	System of AVCP	System 1
6.	Harmonised standard	EN 12101-8:2011
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2023/0030 Assessment Report of Performance of Construction Product No. P-1391-CPR-2023/0030

7a.	<b>Declared performances – fire resistance classification</b> Essential characteristics in accordance with EN 12101-8:2011, art. 4.1.1	
<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Performance – class of fire resistance</i>
Shaft from concrete or aerated concrete <sup>1)</sup> – wall thickness min. 70 mm	Mortar or gypsum <sup>1)</sup>	EI 120 (V <sub>ed</sub> i↔o) S1500C <sub>300</sub> AAmulti <sup>2),3)</sup>
	Mastic <sup>1)</sup>	
	Installation frame – mortar or gypsum <sup>1)</sup>	
	Installation frame – mastic <sup>1)</sup>	

(table continues)

<sup>1)</sup> Refer to [Technical documentation](#) for the details of the installation type / installation system.

<sup>2)</sup> In practice, the dampers will never be in open position at the beginning of danger from smoke.

<sup>3)</sup> Damper tested at increased vacuum of 500 Pa.

(continuation of the table)

7a. <b>Declared performances – fire resistance classification</b> Essential characteristics in accordance with EN 12101-8:2011, art. 4.1.1		
<i>Fire separating construction</i>	<i>Installation type, installation system</i>	<i>Performance – class of fire resistance</i>
Shaft from fire-resistant panels <sup>1)</sup> – specific weight min 500 kg/m – shaft wall thickness min. 30 mm while respecting shaft wall thickness in acc. with the given duct fire resistance class for the given pressure <sup>4)</sup> ; e.g.: <ul style="list-style-type: none"> <li>• 50 mm PROMATECT L 500</li> <li>• 45 mm THERMAX SL (Tecniver)</li> <li>• 45 mm GEOTEC S</li> <li>• 45 mm GEOFLAM F</li> <li>• 35 mm GEOFLAM F Light</li> </ul>	Mortar or gypsum <sup>1)</sup>	EI 120 (v <sub>ed</sub> i↔o) S1500C <sub>300</sub> AAmulti <sup>2),3)</sup>
	Mastic <sup>1)</sup>	
	Installation frame – mortar or gypsum <sup>1)</sup>	
	Installation frame – mastic <sup>1)</sup>	
Shaft from fire-resistant panels <sup>1)</sup> – specific weight min 500 kg/m – shaft wall thickness min. 30 mm while respecting shaft wall thickness in acc. with the given duct fire resistance class for the given pressure <sup>4)</sup> ; e.g.: <ul style="list-style-type: none"> <li>• 40 mm PROMATECT L 500</li> <li>• 45 mm THERMAX SL (Tecniver)</li> <li>• 45 mm GEOTEC S</li> <li>• 35 mm GEOFLAM F</li> <li>• 35 mm GEOFLAM F Light</li> </ul>	Mortar or gypsum <sup>1)</sup>	EI 90 (v <sub>ed</sub> i↔o) S1500C <sub>300</sub> AAmulti <sup>2),3)</sup>
	Mastic <sup>1)</sup>	
	Installation frame – mortar or gypsum <sup>1)</sup>	
	Installation frame – mastic <sup>1)</sup>	
Shaft from fire-resistant panels <sup>1)</sup> – specific weight min 500 kg/m – shaft wall thickness min. 30 mm while respecting shaft wall thickness in acc. with the given duct fire resistance class <sup>4)</sup> for the given pressure; e.g.: <ul style="list-style-type: none"> <li>• 30 mm PROMATECT L 500</li> <li>• 45 mm THERMAX SL (Tecniver)</li> <li>• 30 mm GEOTEC S</li> <li>• 30 mm GEOFLAM F</li> <li>• 35 mm GEOFLAM F Light</li> </ul>	Mortar or gypsum <sup>1)</sup>	EI 60 (v <sub>ed</sub> i↔o) S1500C <sub>300</sub> AAmulti <sup>2),3)</sup>
	Mastic <sup>1)</sup>	
	Installation frame – mortar or gypsum <sup>1)</sup>	
	Installation frame – mastic <sup>1)</sup>	
Shaft from fire-resistant panels <sup>1)</sup> – specific weight min 500 kg/m – shaft wall thickness min. 30 mm while respecting shaft wall thickness in acc. with the given duct fire resistance class <sup>4)</sup> for the given pressure; e.g.: <ul style="list-style-type: none"> <li>• 35 mm THERMAX SL (Tecniver)</li> </ul>	Mortar or gypsum <sup>1)</sup>	EI 60 (v <sub>ed</sub> i↔o) S500C <sub>300</sub> AAmulti <sup>2)</sup>
	Mastic <sup>1)</sup>	
	Installation frame – mortar or gypsum <sup>1)</sup>	
	Installation frame – mastic <sup>1)</sup>	

<sup>1)</sup> Refer to [Technical documentation](#) for the details of the installation type / installation system.

<sup>2)</sup> In practice, the dampers will never be in open position at the beginning of danger from smoke.

<sup>3)</sup> Damper tested at increased vacuum of 500 Pa.


<sup>4)</sup> Duct system must be tested and classified in accordance with EN 13501-4.

7b.	<b>Declared performances – essential characteristics</b> Essential characteristics in accordance with EN 15650:2010, art. 4.1.1	
<i>Essential characteristics</i>	<i>Requirements (provisions of harmonised standard EN 12101-8:2011)</i>	<i>Performance (level or class) / Compliance with the requirements</i>
Nominal activation conditions/sensitivity	4.2.1.3	Conforms
Response delay (response time)	4.2.1.4	Conforms
Operational reliability	4.3.2.2	C 300 – conforms
Fire resistance – integrity (E)	4.1.1 a)	E – conforms
Fire resistance – insulation (EI)	4.1.1 b)	EI – conforms
Fire resistance – smoke leakage (ES)	4.1.1 c)	EIS – conforms
Fire resistance – mechanical stability (under E)	4.1.1 d)	Conforms
Fire resistance – maintenance of cross section (under E)	4.1.1 e)	Conforms
Fire resistance – high operational temperature	4.1.1 f)	NPD – No performance determined
Durability – of response delay	4.3.2.1	Conforms
Durability – of operational reliability	4.3.2.2	C 300 – conforms

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 2025-01-02

  
Mgr. Jan Mičan  
CEO, Ppa  
MANDÍK, a.s.

<b>Declared performances – other characteristics</b>		
<i>Characteristics</i>	<i>Technical standard</i>	<i>Performance (level or class) / Compliance with the requirements</i>
Damper blade tightness	EN 1751:2024	Class 3
Damper casing tightness	EN 1751:2024	N/A