

1.	Unique identification code of the product-type	FDMA-PM
2.	Products	Dampers – Fire dampers
	Intended use	Fire safety. To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications TPM 145/20
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 mandik@mandik.cz , www.mandik.com
5.	System of AVCP	System 1
6.	Harmonised standard	EN 15650:2010
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek, Czech Republic
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2024/0010 Assessment Report of Performance of Construction Product No. P-1391-CPR-2024/0010

7a.	Declared performances – fire resistance classification Essential characteristics in accordance with EN 15650:2010, art. 4.1.1	
<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Performance – class of fire resistance</i>
Solid wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum ¹⁾	If stated on the purchase order EI 120 (v _e i↔o) S, otherwise EI 90 (v _e i↔o) S
	Battery – mortar or gypsum ¹⁾	EI 90 (v _e i↔o) S
	Installation next to wall, ceiling – mortar or gypsum and mineral wool ¹⁾	
	Installation next to wall, ceiling – mortar or gypsum ¹⁾	
	Installation next to wall, ceiling – installation frame R3, R4, R5	
	Mineral wool with fire protection mastic and cement lime plate ¹⁾	
	Installation frame R1, R2, R3, R4, R5 ¹⁾	
	Ablative Coated Batt ¹⁾	
Battery – installation frame R1 ¹⁾		

(table continues)

1) Refer to [Technical documentation](#) for the details of the installation type / installation system.

(continuation of the table)

<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Performance – class of fire resistance</i>
Solid wall construction – damper remote from the wall – 100 mm min. wall thickness	Insulation of the duct with cement lime plates – installation frame R6 ^{1]}	EI 90 (v _e i↔o) S
	Insulation of the duct with mineral wool + Mineral wool with fire protection mastic and cement lime plate ^{1]}	
	Insulation of the duct with mineral wool + mortar or gypsum ^{1]}	EI 45 (v _e i↔o) S
	Insulation of the duct with mineral wool + Mineral wool with fire protection mastic ^{1]}	
Gypsum plasterboard wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum ^{1]}	If stated on the purchase order EI 120 (v _e i↔o) S, otherwise EI 90 (v _e i↔o) S
	Battery – mortar or gypsum ^{1]}	EI 90 (v _e i↔o) S
	Installation next to wall, ceiling – mortar or gypsum and mineral wool ^{1]}	
	Installation next to wall, ceiling – mortar or gypsum ^{1]}	
	Installation next to wall, ceiling – installation frame R1, R2, R5 and mineral wool ^{1]}	
	Mineral wool with fire protection mastic and cement lime plate ^{1]}	
	Installation frame R1, R2, R3, R4, R5 ^{1]}	
	Ablative Coated Batt ^{1]}	
	Battery – installation frame R1 ^{1]}	
Flexible ceiling – installation frame R7 ^{1]}		
Gypsum plasterboard wall construction – damper remote from the wall – 100 mm min. wall thickness	Insulation of the duct with mineral wool + Mineral wool with fire protection mastic and cement lime plate ^{1]}	EI 90 (v _e i↔o) S
	Insulation of the duct with mineral wool + mortar or gypsum ^{1]}	EI 45 (v _e i↔o) S
	Insulation of the duct with mineral wool + Mineral wool with fire protection mastic ^{1]}	
Solid ceiling construction – damper in the ceiling – ceiling thickness min. 150 mm	Mortar or gypsum ^{1]}	If stated on the purchase order EI 120 (h _o i↔o) S, otherwise EI 90 (h _o i↔o) S
	Battery – mortar or gypsum ^{1]}	EI 90 (h _o i↔o) S
	Mineral wool with fire protection mastic and cement lime plate ^{1]}	
	Installation frame R1, R2, R3, R4, R5 ^{1]}	
	Ablative Coated Batt ^{1]}	
Battery – installation frame R2 ^{1]}		
Solid ceiling construction – damper remote from the ceiling – ceiling thickness min. 150 mm	Insulation of the duct with mineral wool + mortar or gypsum ^{1]}	EI 90 (h _o i↔o) S
	Concrete ^{1]}	
	Concrete with installation frame R5 ^{1]}	
	Insulation of the duct with cement lime plates – installation frame R6 ^{1]}	
Thin shaft construction – 100 mm min. wall thickness	Mortar or gypsum ^{1]}	EI 90 (v _e i↔o) S
	Installation frame R1 ^{1]}	


1] Refer to [Technical documentation](#) for the details of the installation type / installation system.

7b. Declared performances – essential characteristics		
<i>Essential characteristics</i>	<i>Requirements (provisions of the harmonised standard EN 15650:2010)</i>	<i>Performance (lever or class) / Compliance with the requirements</i>
Nominal activation conditions/sensitivity:	4.2.1.2	Conforms
– sensing element load bearing capacity	4.2.1.2.2	Conforms
– sensing element response temperature	4.2.1.2.3	Conforms
Response delay (response time): – closure time	4.2.1.3	Conforms
Operational reliability: – cycling	4.3.1, a)	50 cycles – conforms
Durability of response delay: – sensing element response to temperature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	Conforms
Durability of operational reliability: – opening and closing cycle tests	4.3.3.2	Dampers with control mechanisms - manual Mandík M: NPD - Mandík MODULAR: C ₃₀₀ - Belimo, Gruner, Schischek: C _{10,000}

The performance of the product identified above is in conformity with the set of declared performance/s.
This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 2025-01-02


Jan Mičan
CEO, Ppa
MANDÍK, a.s.

7c. Declared performances – other characteristics		
<i>Characteristics</i>	<i>Technical standard</i>	<i>Performance (lever or class) / Compliance with the requirements</i>
Resistance against corrosion	EN 15650:2010, art. 4.2.2 EN 15650:2010, Annexe B	Conforms
Damper blade tightness	EN 1751:2024	Class 2
Damper casing tightness	EN 1751:2024	Class ATC 3 (old marking “C”)

Additional provisions for use of the product in Austria

The product-type products meet also all requirements of ÖNORM H 6025 standard, cf. Assessment Report of Performance of Construction Product No. P-1391-CPR-2024/0010.